

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
5/19/1992	5/19/1992	32487 YUCAIPA BOULEVARD, YUCAIPA	7-11 STORE #17814	UNDERGROUND STORAGE TANK LEAK: DIESEL	CASE CLOSED
4/18/2002	9/25/2001	1020 S. BRISTOL STREET, SANTA ANA	7-ELEVEN STORE	UNDERGROUND STORAGE TANK LEAK: GASOLINE	POLLUTION CHARACTERIZATION
4/10/2002	8/28/2001	1725 BROOKHURST, SOUTH, ANAHEIM	AMERICANA	UNDERGROUND STORAGE TANK LEAK: GASOLINE	POLLUTION CHARACTERIZATION
12/21/2001	1/1/1965	25330 THIRD STREET, HIGHLAND	ARCO # 5541	UNDERGROUND STORAGE TANK LEAK: GASOLINE	SITE WORKPLAN UNDERWAY
7/30/2001	1/1/1965	700 STATE COLLEGE, ANAHEIM	ARCO #1994	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
8/24/1999	8/24/1999	1565 4TH STREET, ONTARIO	ARCO STATION # 1981	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
12/5/1989	9/12/1989	539 REDLANDS BOULEVARD, REDLANDS	ARCO STATION #6052	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
3/3/1999	2/18/1999	539 REDLANDS BOULEVARD, REDLANDS	ARCO STATION #6052	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
8/22/2000	7/6/2000	25717 BASELINE STREET, HIGHLAND	ARCO STATION #9699	UNDERGROUND STORAGE TANK LEAK: GASOLINE	POLLUTION CHARACTERIZATION
4/10/2002	1/4/2002	20602 LAKE FOREST DRIVE, LAKE FOREST	BEACON BAY CAR WASH	UNDERGROUND STORAGE TANK LEAK: GASOLINE	SITE WORKPLAN UNDERWAY
12/18/1992	12/18/1992	417 GRENFALL LANE, BIG BEAR CITY	BIG BEAR CITY CSD	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
9/25/2000	9/25/2000	10002 ALMOND AVENUE, FONTANA	BTE FUEL STOP	UNDERGROUND STORAGE TANK LEAK: DIESEL	POLLUTION CHARACTERIZATION
3/2/1990	3/2/1990	15513 VALLEY BOULEVARD, FONTANA	CARNIVAL TIME SHOWS	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
11/9/1999	11/3/1999	1035 VINEYARD AVENUE, ONTARIO	CITY RENTALS	UNDERGROUND STORAGE TANK LEAK: LEAD	SITE WORKPLAN SUBMITTED
2/11/2002	12/11/2001	1312 RADCLIFFE CIRCLE, CORONA	FIELDSTONE COMMUNITIES, INC, LOT 41	UNDERGROUND STORAGE TANK LEAK: DIESEL	REMEDIAL ACTION UNDERWAY
8/31/1992	7/17/1992	16173 HIGHLAND AVENUE, FONTANA	FORMER GAS STATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED

\*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger. This report contains some older UST cases that were not previously reported in the Geotracker/LUSTIS Databases. These cases were added as part of an ongoing reconciliation between the Geotracker/GEIMS, DOD, and Local Agency databases.

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
	1/1/1965	1001 STATE COLLEGE, ANAHEIM	FORMER TEXACO STATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
4/10/2002	4/2/2002	1945 W. 4TH STREET, SAN BERNARDINO	FOURTH ST ROCK CRUSHER	UNDERGROUND STORAGE TANK LEAK: DIESEL	SITE WORKPLAN SUBMITTED
4/29/1997	4/29/1997	12191 VALLEY VIEW STREET, GARDEN GROVE	GARDEN GROVE FIRE STATION #4	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
9/21/2000	10/1/1998	16081 VALLEY BOULEVARD, FONTANA	GASCO #595	UNDERGROUND STORAGE TANK LEAK: GASOLINE	POLLUTION CHARACTERIZATION
8/21/1987	8/13/1987	3045 G STREET, ONTARIO	GREENS INDUSTRIAL PAINTING	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
10/27/1987	10/27/1987	415 5TH STREET, SAN BERNARDINO	LA MANCHA DEVELOPMENT	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
3/2/2001	10/27/1997	1455 9TH STREET, UPLAND	LAIDLAW TRANSIT INC.	UNDERGROUND STORAGE TANK LEAK: DIESEL	POLLUTION CHARACTERIZATION
12/21/1999	12/21/1999	MILE 39.01 HIGHWAY 18, RUNNING SPRINGS	LAKEVIEW MAINTENANCE STATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE	SITE WORKPLAN UNDERWAY
1/4/1991	1/4/1991	11325 LOMA LINDA DRIVE, LOMA LINDA	LOMA LINDA FIRE DEPARTMENT	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
11/18/1993	11/18/1993	11234 ANDERSON STREET, LOMA LINDA	LOMA LINDA MEDICAL CENTER	UNDERGROUND STORAGE TANK LEAK: DIESEL	CASE CLOSED
3/22/2001	5/9/2000	503 EAST PALMYRITA AVENUE, HIGHGROVE	LYNN PARCEL (FORMER CITRUS GROVE)	UNDERGROUND STORAGE TANK LEAK: GASOLINE	POST REMEDIAL ACTION MONITORING
3/18/2002	12/15/1989	SITE 43 35TH STREET, RIVERSIDE	MARCH AFB (FORMER)	UNDERGROUND STORAGE TANK LEAK: REGULR GASOLINE	REMEDIAL ACTION UNDERWAY
9/24/1998	8/7/1998	IRP S34 NW CORNOR OF FUELING FACILITY, MARCH AIR RESERVE BASE	MARCH AIR RESERVE BASE	UNDERGROUND STORAGE TANK LEAK: BENZENE	CASE CLOSED
7/25/2001	1/1/1965	400 LAKEVIEW, ANAHEIM	MOBIL #18-833	UNDERGROUND STORAGE TANK LEAK: GASOLINE	POLLUTION CHARACTERIZATION
12/6/2001	12/6/2001	3180 BARRANCA PARKWAY, IRVINE	ORANGE COUNTY FIRE STATION #6	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED

\*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger. This report contains some older UST cases that were not previously reported in the Geotracker/LUSTIS Databases. These cases were added as part of an ongoing reconciliation between the Geotracker/GEIMS, DOD, and Local Agency databases.

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
10/4/1989	5/23/1989	941 INLAND CENTER DRIVE, SAN BERNARDINO	TFI APPLIANCE SERVICE	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
9/17/1990	9/17/1990	25717 BASELINE STREET, HIGHLAND	THRIFTY OIL COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE	CASE CLOSED
4/20/2000	4/20/2000	4325 GUASTI ROAD, ONTARIO	TRAVEL CENTERS OF AMERICA EAST	UNDERGROUND STORAGE TANK LEAK: GASOLINE	SITE WORKPLAN UNDERWAY
1/2/1998	5/19/1997	USMCAS TUSTIN, TUSTIN	USMCAS TUSTIN UST 181	UNDERGROUND STORAGE TANK LEAK: WATER & OIL MIX	CASE CLOSED
9/11/1996	12/18/1995	USMCAS TUSTIN, TUSTIN	USMCAS TUSTIN UST 226	UNDERGROUND STORAGE TANK LEAK: HYDRAULIC OIL	CASE CLOSED
11/28/1995	11/27/1995	USMCAS TUSTIN, TUSTIN	USMCAS TUSTIN UST 27A AND 27B	UNDERGROUND STORAGE TANK LEAK: DIESEL	POST REMEDIAL ACTION MONITORING
12/1/1995	11/29/1995	USMCAS TUSTIN, TUSTIN	USMCAS TUSTIN UST 28A	UNDERGROUND STORAGE TANK LEAK: DIESEL	CASE CLOSED
2/4/1996	11/29/1995	USMCAS TUSTIN, TUSTIN	USMCAS TUSTIN UST 506	UNDERGROUND STORAGE TANK LEAK: DIESEL	CASE CLOSED

\*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger. This report contains some older UST cases that were not previously reported in the Geotracker/LUSTIS Databases. These cases were added as part of an ongoing reconciliation between the Geotracker/GEIMS, DOD, and Local Agency databases.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/6/02	2/6/02	26564	Irvine Ranch Water District	6134 Oak Canyon, Irvine, Orange County	TRW	15,000,000	An estimated 15,000,000 gallons of tertiary recycled water (TRW) was released due to backwash valve failure. All of the spill discharged into a nearby storm drain and into the ocean. The valve was repaired and the affected area was cleaned up by IRWD staff.
3/19/02	3/19/02	24013	City of La Habra Public Utilities	Verna Ave & Orange St, La Habra, Orange County	SSO	1,250	An estimated 1,250 gallons of sewage overflowed from a manhole due to unspecified blockage. All 1,250 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by City of La Habra staff.
3/20/02	3/20/02	26560	Private Property Owner	San Joaquin & La Serena, Irvine, Orange County	TRW	12,000	An estimated 12,000 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by the private property owner.
3/23/02	3/23/02	25533	Private Property Owner	12 Machly, Irvine, Orange County	TRW	1,400	An estimated 1,400 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All 1,400 gallons of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by the private property owner.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/24/02	3/24/02	25758	Private Property Owner	4900 E Chapman, Orange, Orange County	SSO	750	An estimated 750 gallons of sewage overflowed from a private lateral due to grease blockage. All 750 gallons of the spill discharged into a nearby storm drain. None of the spill was recovered. The blockage was cleared and the affected area was cleaned up by the private property owner.
3/25/02	3/25/02	26490	Irvine Ranch Water District	23095 Scotia Sea, Irvine, Orange County	TRW	1,800	An estimated 1,800 gallons of tertiary recycled water (TRW) was released from a line break. All 1,800 gallons of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by IRWD staff.
3/26/02	3/26/02	25760	Private Property Owner	Truman & Roosevelt, Irvine, Orange County	TRW	675	An estimated 675 gallons of tertiary recycled water (TRW) was released from a private irrigation system due to a line break. All 675 gallons of the spill discharged into a nearby storm drain. The broken line was repaired and the affected area was cleaned up by the private property owner.
3/28/02	3/28/02	25761	Eastern Municipal Water District	Tabor & Ironwood, Moreno Valley, Riverside County	SSO	640	An estimated 640 gallons of sewage overflowed from a manhole due to an unspecified blockage. All 640 gallons of the spill were contained and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by Eastern Municipal Water District staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/1/02	4/1/02	26559	City of Irvine	Barranca, Irvine, Orange County	TRW	4,500	An estimated 4,500 gallons of tertiary recycled water (TRW) was released from a broken sprinkler head. All 4,500 gallons of the spill discharged into a nearby storm drain. The sprinkler was repaired and the affected area was cleaned up by City staff.
4/3/02	4/3/02	25522	County Cucamonga Water District	Beryl St & 210 Freeway, Rancho Cucamonga, San Bernardino	SSO	4,000	An estimated 4,000 gallons of sewage overflowed from a manhole due to debris blockage. All 4,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up and disinfected by Cucamonga County Water District.
4/3/02	4/3/02	26612	IRWD	Misty Run & West Yale Loop, Irvine, Orange County	TRW	2,250	An estimated 2,250 gallons of tertiary recycled water (TRW) was released from a broken sprinkler head. All of the spill discharged into a nearby storm drain. The sprinkler head was repaired and the affected area was cleaned up by IRWD staff.
4/3/02	4/3/02	26614	IRWD	Dimension Dr, Lake Forest, Orange County	TRW	1,500	An estimated 1,500 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by IRWD staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/4/02	4/4/02	26338	Private Property Owner	Irvine Center Dr, Irvine, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a manhole due to a grease blockage. All 600 gallons of the spill discharged into a nearby storm drain. The affected area was cleaned up by the private property owner.
4/4/02	4/4/02	26554	Irvine Ranch Water District	Irvine Center Dr & Irvine Spectrum, Irvine, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to debris and grease blockage. All 1,000 gallons of the spill ponded. The ponded sewage was recovered and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by IRWD staff.
4/4/02	4/4/02	26613	IRWD	Rim Gate Rd, Lake Forest, Orange County	TRW	4,800	An estimated 4,800 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by IRWD staff.
4/10/02	4/9/02	26561	City of Riverside	4320 Brentwood Ave, Riverside, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 250 gallons of the spill were contained, recovered, and returned to the operational sewer system, and the rest of the spill was not recovered and discharged into a local dry storm drain where it percolated. The blockage was cleared and the affected area was cleaned up by City staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/11/02	4/11/02	26562	City of Ontario	1060 Wineville, City of Ontario, San Bernardino County	SSO	1,080	An estimated 1,080 gallons of sewage overflowed from a manhole due to paper blockage. 20% of the spill was contained, recovered, and returned to the operational sewer system while the rest discharged into a local storm drain. The blockage was cleared and the affected area was cleaned up by City of Ontario staff.
4/12/02	4/12/02	26565	EMWD	Indian Ave & JFK Parkway, Moreno Valley, Riverside County	SSO	2,550	An estimated 2,550 gallons of sewage overflowed from a manhole due to grease blockage. All 2,550 gallons of the spill discharged into a local dry storm drain where it percolated. The blockage was cleared and the affected area was cleaned up by EMWD staff.
4/12/02	4/12/02	26566	Private Property Owner	4951 Paseo Segovia, Irvine, Orange County	TRW	1,200	An estimated 1,200 gallons of tertiary recycled water (TRW) was released from a sprinkler line break. All of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by the private property owner.
4/15/02	4/15/02	26394	Private Property Owner	12622 Kingsview Rd, Cowan Heights, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to unspecified blockage. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by the private property owner.



## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/16/02	4/16/02	26337	Irvine Ranch Water District	26160 Enterprise Way, Irvine, Orange County	TRW	3,600	An estimated 3,600 gallons of tertiary recycled water (TRW) was released from a line break. All 3,600 gallons of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by IRWD staff.
4/17/02	4/17/02	26335	Orange County Sanitation District	Euclid @ 405 Freeway, Fountain Valley, Orange County	SSO	8,000	An estimated 8,000 lbs of treated sludge spilled from a dump truck due to a vehicle accident. All 8,000 lbs of the spill were contained and returned to an Orange County water treatment plant. The affected area was cleaned up by Orange County Sanitation District staff.
4/17/02	4/17/02	26567	County Cucamonga Water District	8675 Baseline St, Rancho Cucamonga, San Bernardino County	SSO	1,100	An estimated 1,100 gallons of sewage overflowed from a private lateral due to debris blockage. Approximately 900 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by CCWD staff.
4/21/02	4/21/02	25762	Eastern Municipal Water District	Winding Rd & Glen View Dr, Moreno Valley, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to unspecified reasons. All 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. The affected area was cleaned up and disinfected by Eastern Municipal Water District staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/22/02	4/21/02	24534	Eastern Municipal Water District	Winding Rd @ Glenview, Moreno Valley, Riverside County	SSO	1,600	An estimated 1,600 gallons of sewage overflowed from a manhole due to root blockage. All 1600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by EMWD staff.
4/22/02	4/22/02	24518	City of Orange	2050 N Tustin Ave, Orange, Orange County	SSO	1,431	An estimated 1,431 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 150 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The affected area was cleaned up by City staff.
4/22/02	4/22/02	24533	Private Property Owner	3304 Main St, Irvine, Orange County	TRW	2,400	An estimated 2,400 gallons of tertiary recycled water (TRW) was released from a sprinkler line break. All 2,400 gallons of the spill discharged into a nearby storm drain. The affected area was cleaned up by the private property owner.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/22/02	4/22/02	25532	Private Property Owner	2050 N Tustin, Orange, Orange County	SSO	1,431	An estimated 1,431 gallons of sewage overflowed from a manhole due to unspecified blockage. Approximately 150 gallons of the spill were contained and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Orange staff.
4/27/02	4/27/02	25755	Private Property Owner	19801 Shorecliff Ln, Huntington Beach, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to unspecified blockage. Approximately 350 gallons of the spill were contained and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by the private property owner.
4/27/02	4/27/02	25759	City of Stanton	7731 Santa Catalina, Stanton, Orange County	SSO	700	An estimated 700 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 500 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Stanton staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/2/02	5/1/02	25529	City of Riverside	3348 Comer Ave, Riverside, Riverside County	SSO	1,600	An estimated 1,600 gallons of sewage overflowed from a private lateral due to debris blockage. Approximately 320 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Riverside staff.
5/3/02	5/3/02	26569	City of Fullerton	2701 Coronado Dr, Fullerton, Orange County	SSO	898	An estimated 898 gallons of sewage overflowed from a manhole due to unspecified blockage. Approximately 298 gallons of the spill were contained, recovered and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by City of Fullerton staff.
5/5/02	5/5/02	25531	IRWD	62 Coral Leaf, Newport Beach, Orange County	TRW	1,500	An estimated 1,500 gallons of tertiary recycled water (TRW) was released from an irrigation line break. All 1,500 gallons of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by IRWD staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/7/02	5/6/02	26400	El Toro Water District	23552 Moulton Pkwy, Laguna Woods, Orange County	TRW	91,450	An estimated 91,450 gallons of tertiary recycled water (TRW) was released from an irrigation line break. Approximately 1,100 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by ETWD staff.
5/8/02	5/8/02	25523	City of Stanton	12710 Beach Blvd, Stanton, Orange County	SSO	4,000	An estimated 4,000 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 3,300 gallons of the spill were contained, recovered and returned to the operational sewer sytem, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Stanton staff.
5/8/02	5/8/02	25527	City of Ontario	1000 block of East I St, Ontario, San Bernardino County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to grease blockage. All 3,000 gallons of the spill were contained and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by City of Ontario staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/8/02	5/8/02	25524	IRWD	15 Corporate Park Dr, Irvine, Orange	TRW	6,000	An estimated 6,000 gallons of tertiary recycled water (TRW) was released from an irrigation pipe break. All 6,000 gallons of the spill discharged into a nearby storm drain. The pipe was repaired and the affected area was cleaned up by IRWD staff.
5/13/02	5/13/02	26336	City of Newport Beach	Jamboree & East Bluff Dr, Newport Beach, Orange County	TRW	8,000	An estimated 8,000 gallons of tertiary recycled water (TRW) was released from a line break. All 8,000 gallons of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by City of Newport Beach staff.
5/15/02	5/10/02	26334	Private Property Owner, Crabby Bob's Restaurant	12206 Central Ave; City-Chino; San Bernardino County	SSO	900	An estimated 900 gallons of sewage overflowed from a private lateral due to grease blockage. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by the private property owner.
5/18/02	5/18/02	26340	Private Property Owner	Alton & San Marino, Irvine, Orange County	TRW	2,000	An estimated 2,000 gallons of tertiary recycled water (TRW) was released from an irrigation system sprinkler. All 2,000 gallons of the spill discharged into a nearby storm drain. The affected area was cleaned up by the private property owner.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/18/02	5/18/02	26341	Private Property Owner	Michaelson, Irvine, Orange County	TRW	1,050	An estimated 1,050 gallons of tertiary recycled water (TRW) was released from a line break. All 1,050 gallons of the spill discharged into nearby storm drain. The line was repaired and the affected area was cleaned up by the private property owner.
5/20/02	5/20/02	26395	Private Property Owner	12075 Garden Grove Blvd, Garden Grove, Orange County	SSO	1,654	An estimated 1,654 gallons of sewage overflowed from a private lateral due to grease blockage. Approximately 754 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by the private property owner.
5/20/02	5/20/02	26486	Private Property Owner	159 W. Yale Loop, Irvine, Orange County	TRW	1,000	An estimated 1,000 gallons of tertiary recycled water (TRW) was released from a broken control valve. All 1,000 gallons of the spill discharged into a nearby storm drain. The valve was repaired and the affected area was cleaned up by the private property owner .

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/22/02	5/22/02	26396	City of Stanton	8337 Monroe, Stanton, Orange County	SSO	700	An estimated 700 gallons of sewage overflowed from a manhole due to debris blockage. Approximately 500 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Stanton staff.
5/25/02	5/25/02	26397	Private Property Owner	Turtle Rock Drive, Irvine, Orange County	TRW	1,800	An estimated 1,800 gallons of tertiary recycled water (TRW) was released from a broken sprinkler head. All 1,800 gallons of the spill discharged into a nearby storm drain. The sprinkler head was repaired and the affected area was cleaned up by the private property owner.
5/27/02	3/27/02	25528	East Valley Water District	7265 Leedom Dr, Highland, San Bernardino County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a manhole due to grease blockage. All 2,000 gallons of the spill discharged into a local storm drain and percolated into the ground. The blockage was cleared and the affected area was cleaned up by EVWD staff.



## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
5/27/02	5/27/02	26399	City of Stanton	7327 Rutledge, Stanton, Orange County	SSO	800	An estimated 800 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 600 gallons of the spill were contained, recovered and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Stanton staff.
6/3/02	6/3/02	26485	Private Property Owner	Jamboree & Bryan, Tustin, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to grease blockage. All 1,000 gallons of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by the private property owner.
6/6/02	6/6/02	26557	City of Santa Ana	4117 W McFadden Ave, Santa Ana, Orange County	SSO	580	An estimated 580 gallons of sewage overflowed from a private lateral due to grease blockage. Approximately 240 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Santa Ana staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/8/02	6/8/02	26330	City of Riverside	Riverside STP, Riverside, Riverside County	TCR	1,250,000	An estimated 1,250,000 gallons of high total chlorine residual (TCR) effluent discharged into the Santa Ana River from the Riverside Treatment Plant due to SO2 injection system failure. Chlorine residual >0.1 mg/L was detected for approximately 62 minutes, peaking at 1.14 mg/L. Two miles of effluent channel were inspected and no adverse environmental impact was observed. Investigation of this incident is ongoing.
6/12/02	6/12/02	26487	City of Corona	Cajalco Rd & Temescal Canyon Rd, Corona, Orange County	SSO	10,951	An estimated 10,951 gallons of sewage overflowed from a sewer line break caused by construction. Approximately 1,063 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into surrounding soil where it percolated. The line was repaired and the affected area was cleaned up and disinfected by City of Corona staff.
6/12/02	6/12/02	26555	City of Riverside	2150 Fariview Ave, Riverside, Riverside County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a manhole due to debris blockage. Approximately 400 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by City of Riverside staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notific. No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
6/15/02	6/15/02	26484	Private Property Owner	Turtle Rock & Sierrago, Irvine, Orange County	TRW	2,500	An estimated 2,500 gallons of tertiary recycled water (TRW) was released from a broken valve. All 2,500 gallons of the spill discharged into a nearby storm drain. The valve was repaired and the affected area was cleaned up by the private property owner.
6/24/02	6/23/02	26563	City of Beaumont	248 Elm Ave, Beaumont, Riverside County	SSO	5,000	An estimated 5,000 gallons of sewage overflowed from a sewer line break. Approximately 2,000 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a nearby storm drain. The line was repaired and the affected area was cleaned up by City of Beaumont staff.